


Babcock Power Inc.

OFA Flow Measuring Devices

- ❑ OFA feeder duct probes are automatically purged by the CAMS
- ❑ OFA port probes
 - ✓ Periodically blow compressed air through tubes to remove ash accumulation.
 - once per month is suggested
 - actual cleaning frequency is site specific
 - ensure gauge is isolated before pressurizing probe



Babcock Power Inc.